

LOCUST VALLEY WATER DISTRICT  
2022 WATER QUALITY DATA

PARAMETERS (mg/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 4 N-00118		WELL NO. 5 N-00119 <sup>(2)</sup>		WELL NO. 6 N-01651 <sup>(2)</sup>		WELL NO. 7 N-05152 <sup>(1)</sup>		WELL NO. 8 N-07665 <sup>(1)</sup>		WELL NO. 9 N-014223 <sup>(1)</sup>	
			MAX. RESULT	AVG. RESULT	MAX. RESULT (raw/treated)	AVG. RESULT (raw/treated)	MAX. RESULT (raw/treated)	AVG. RESULT (raw/treated)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b>INORGANIC</b>														
ARSENIC	10.0 ug/l	3.0 ug/l	OUT OF SERVICE		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
BARIUM	2.0 mg/l	0.2 mg/l		0.078/0.078	0.078/0.078	0.019/0.019	0.019/0.019	0.022	0.022	0.029	0.029	0.087	0.087	
CADMIUM	5.0 ug/l	5.0 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
CHROMIUM	0.10 mg/l	0.01 mg/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
COPPER	[1.3] mg/l	0.02 mg/l		ND	ND	0.011/ND	0.011/ND	0.0048	0.0048	0.0078	0.0078	0.0099	0.0099	
FLUORIDE	2.2 mg/l	0.1 mg/l		ND	ND	ND	ND	0.18	0.18	ND	ND	ND	ND	
LEAD	[15.0] ug/l	1.0 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
MERCURY	2.0 ug/l	0.2 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
LANGLIER SATURATION INDEX	None	None		-3.27/-3.3	-3.27/-3.3	-3.42/-3.44	-3.42/-3.44	-3.22	-3.22	-3.36	-3.36	-2.84	-2.84	
SELENIUM	50 ug/l	5.0 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
SILVER	0.1 mg/l	0.01 mg/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
SODIUM	**20/270 mg/l	0.2 mg/l		12.0/12.0	12.0/12.0	8.3/8.4	8.3/8.4	9.7	9.7	9.6	9.6	14.9	14.9	
ZINC	5.0 mg/l	0.02 mg/l		ND/0.035	ND/0.035	ND	ND	ND	ND	ND	ND	0.034	0.034	
COLOR	15 Units	5 Units		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
TURBIDITY	5 Units	1 Unit		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
ODOR	3 Units	0 Units		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
IRON	0.3 mg/l	0.02 mg/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
MANGANESE	0.3 mg/l	0.01 mg/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
AMMONIA	None	0.1 mg/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
NITRITE	1.0 mg/l	0.1 mg/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
NITRATE	10.0 mg/l	0.1 mg/l		3.9 <sup>(8)</sup> /4.2 <sup>(8)</sup>	3.4/3.3	3.0 <sup>(2)</sup> /4.5 <sup>(8)</sup>	3.0/4.0	4.2 <sup>(2)</sup>	4.2	4.4 <sup>(8)</sup>	4.2	4.2 <sup>(2)</sup>	4.2	
CHLORIDE	250 mg/l	1.0 mg/l	23.3/23.7	23.3/23.7	14.7/14.6	14.7/14.6	14.6	14.6	17.0	17.0	38.0 <sup>(4)</sup>	36.2		
TOTAL HARDNESS	None	1.0 mg/l	56.7/56.9	56.7/56.9	38.6/39.1	38.6/39.1	56.0	56.0	61.6	61.6	89.1	89.1		
TOTAL ALKALINITY	None	0 mg/l	26.5/24.5	26.5/24.5	22.8/22.6	22.8/22.6	30.3	30.3	25.0	25.0	36.0	36.0		
pH	None	None	6.2/5.8	6.2/5.8	6.3/6.2	6.3/6.2	7.0	7.0	6.4	6.4	6.3	6.3		
CALCIUM HARDNESS	None	1.0 mg/l	34.7/34.7	34.7/34.7	23.0/23.3	23.0/23.3	33.5	33.5	37.0	37.0	52.7	52.7		
TOTAL DISSOLVED SOLIDS	None	5.0 mg/l	133.0/147.0	133.0/147.0	93.0/106.0	93.0/106.0	114.0	114.0	131.0	131.0	133.0	133.0		
DETERGENTS (MBAS)	None	0.08 mg/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
SULFATE	250 mg/l	5.0 mg/l	20.3/20.5	20.3/20.5	11.0/10.9	11.0/10.9	11.1	11.1	21.6	21.6	30.9	30.9		
FREE CYANIDE	200 ug/l	10.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
ANTIMONY	6.0 ug/l	5.9 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
BERYLLIUM	4.0 ug/l	3.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
CALCIUM	None	1.0 mg/l	13.9/13.9	13.9/13.9	9.2/9.3	9.2/9.3	13.4	13.4	14.8	14.8	21.1	21.1		
MAGNESIUM	None	1.0 mg/l	5.4/5.4	5.4/5.4	3.8/3.8	3.8/3.8	5.5	5.5	6.0	6.0	8.8	8.8		
NICKEL	0.1 mg/l	0.0005 mg/l	ND/0.00057	ND/0.00057	0.0014/0.00079	0.0014/0.00079	0.001	0.001	ND	ND	0.001	0.001		
THALLIUM	2.0 ug/l	0.3 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
PERCHLORATE	18 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	16.8 <sup>(11)</sup>	8.3	ND	ND		

CONT. - CONTAMINANT

ND - NOT DETECTED

NA - NOT ANALYZED

\*\* - 20 mg/l IS THE LIMIT FOR PEOPLE ON HIGHLY RESTRICTED SODIUM DIETS AND 270 mg/l FOR THOSE ON MODERATELY RESTRICTED SODIUM DIETS

[ ] - USEPA/NYS DH ACTION LEVEL

WELL NO. 4 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

LOCUST VALLEY WATER DISTRICT  
2022 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 4 N-00118		WELL NO. 5 N-00119		WELL NO. 6 N-01651		WELL NO. 7 N-05152 <sup>(1)</sup>		WELL NO. 8 N-07665		WELL NO. 9 N-014223	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b>SYNTHETIC ORGANICS CONTAMINANTS</b>														
<b>(SOC)</b>														
LINDANE	0.2 ug/l	0.025 ug/l	<b>OUT OF SERVICE</b>		NOT TESTED		NOT TESTED	ND	ND	ND	ND	ND	ND	ND
HEPTACHLOR	0.4 ug/l	0.025 ug/l		NOT TESTED		NOT TESTED	ND	ND	ND	ND	ND	ND	ND	ND
ALDRIN	5.0 ug/l	0.025 ug/l		NOT TESTED		NOT TESTED	ND	ND	ND	ND	ND	ND	ND	ND
HEPTACHLOR EPOXIDE	0.2 ug/l	0.025 ug/l		NOT TESTED		NOT TESTED	ND	ND	ND	ND	ND	ND	ND	ND
DIELDRIN	2.0 ug/l	0.05 ug/l		NOT TESTED		NOT TESTED	ND	ND	ND	ND	ND	ND	ND	ND
ENDRIN	2.0 ug/l	0.05 ug/l		NOT TESTED		NOT TESTED	ND	ND	ND	ND	ND	ND	ND	ND
METHOXYCHLOR	40.0 ug/l	0.25 ug/l		NOT TESTED		NOT TESTED	ND	ND	ND	ND	ND	ND	ND	ND
TOXAPHENE	3.0 ug/l	2.5 ug/l		NOT TESTED		NOT TESTED	ND	ND	ND	ND	ND	ND	ND	ND
CHLORDANE	2.0 ug/l	0.5 ug/l		NOT TESTED		NOT TESTED	ND	ND	ND	ND	ND	ND	ND	ND
TOTAL PCBs	0.5 ug/l	0.5 ug/l		NOT TESTED		NOT TESTED	ND	ND	ND	ND	ND	ND	ND	ND
PROPACHLOR	50.0 ug/l	1.0 ug/l		NOT TESTED		NOT TESTED	ND	ND	ND	ND	ND	ND	ND	ND
ALACHLOR	2.0 ug/l	1.0 ug/l		NOT TESTED		NOT TESTED	ND	ND	ND	ND	ND	ND	ND	ND
SIMAZINE	4.0 ug/l	0.5 ug/l		NOT TESTED		NOT TESTED	ND	ND	ND	ND	ND	ND	ND	ND
ATRAZINE	3.0 ug/l	0.5 ug/l		NOT TESTED		NOT TESTED	ND	ND	ND	ND	ND	ND	ND	ND
METOLACHLOR	50.0 ug/l	1.0 ug/l		NOT TESTED		NOT TESTED	ND	ND	ND	ND	ND	ND	ND	ND
METRIBUZIN	50.0 ug/l	0.5 ug/l		NOT TESTED		NOT TESTED	ND	ND	ND	ND	ND	ND	ND	ND
BUTACHLOR	50.0 ug/l	1.0 ug/l	NOT TESTED		NOT TESTED	ND	ND	ND	ND	ND	ND	ND	ND	

CONT. - CONTAMINANT

ND - NOT DETECTED

NA - NOT ANALYZED

NOT TESTED - STATE AND COUNTY TESTING REQUIREMENTS INCLUDE TESTING FOR SOC ONCE EVERY 18 MONTHS. THIS WELL NOT TESTED IN 2022.

WELL NO. 4 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

LOCUST VALLEY WATER DISTRICT  
2022 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 4 N-00118		WELL NO. 5 N-00119		WELL NO. 6 N-01651		WELL NO. 7 N-05152 <sup>(1)</sup>		WELL NO. 8 N-07665		WELL NO. 9 N-014223		
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	
<b>SYNTHETIC ORGANICS CONTAMINANTS (SOC)</b>															
<b>(CONT'D.)</b>															
1,4 DIOXANE	1.0 ug/l	0.7 ug/l	OUT OF SERVICE		0.3 <sup>(12)</sup>	0.25	0.33 <sup>(4)</sup>	0.30	0.19 <sup>(4)</sup>	0.17	0.061 <sup>(4)</sup>	0.043	0.1 <sup>(4)</sup>	0.09	
2,4-D	50.0 ug/l	0.25 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
2,4,5-TP (SILVEX)	10.0 ug/l	0.13 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
DINOSEB	7.0 ug/l	0.2 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
DALAPON	200 ug/l	0.7 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
PICLORAM	500 ug/l	0.6 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
DICAMBA	50.0 ug/l	0.08 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
PENTACHLOROPHENOL	1.0 ug/l	0.2 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
HEXACHLOROCYCLOPENTADIENE	50.0 ug/l	0.64 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
bis(2-ETHYLHEXYL)ADIPATE	400 ug/l	1.0 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
bis(2-ETHYLHEXYL)PHTHALATE	6.0 ug/l	3.0 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
HEXACHLOROBENZENE	1.0 ug/l	0.25 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
BENZO(A)PYRENE	0.2 ug/l	0.1 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
ALDICARB SULFONE	2.0 ug/l	1.0 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
ALDICARBSULFOXIDE	4.0 ug/l	1.0 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
ALDICARB	3.0 ug/l	1.0 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
TOTAL ALDICARBS	7.0 ug/l	1.0 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
OXAMYL	200 ug/l	1.0 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
METHOMYL	50.0 ug/l	1.0 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
3-HYDROXYCARBOFURAN	50.0 ug/l	1.0 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
CARBOFURAN	40.0 ug/l	1.0 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
CARBARYL	50.0 ug/l	1.0 ug/l		NOT TESTED					ND	ND	ND	ND	ND	ND	ND
GLYPHOSATE	700 ug/l	10.0 ug/l	NOT TESTED					ND	ND	ND	ND	ND	ND	ND	
DIQUAT	20 ug/l	1.0 ug/l	NOT TESTED					ND	ND	ND	ND	ND	ND	ND	
ENDOTHALL	100 ug/l	50.0 ug/l	NOT TESTED					ND	ND	ND	ND	ND	ND	ND	
1,2-DIBROMOETHANE (EDB)	0.05 ug/l	0.02 ug/l	NOT TESTED					ND	ND	ND	ND	ND	ND	ND	
1,2-DIBROMO-3-CHL.PROPANE	0.2 ug/l	0.02 ug/l	NOT TESTED					ND	ND	ND	ND	ND	ND	ND	
DIOXIN	30 Pg/L	5.0 Pg/L	NOT TESTED					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	

CONT. - CONTAMINANT

ND - NOT DETECTED

NA - NOT ANALYZED

Pg/L - PICOGRAMS PER LITER

NOT TESTED - STATE AND COUNTY TESTING REQUIREMENTS INCLUDE TESTING FOR SOC ONCE EVERY 18 MONTHS. THIS WELL NOT TESTED IN 2021.

WELL NO. 4 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

LOCUST VALLEY WATER DISTRICT  
2022 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 4 N-00118 <sup>(3)</sup>		WELL NO. 5 N-00119 <sup>(16)</sup>		WELL NO. 6 N-01651 <sup>(16)</sup>		WELL NO. 7 N-05152 <sup>(4)</sup>		WELL NO. 8 N-07665 <sup>(4)</sup>		WELL NO. 9 N-014223 <sup>(4)</sup>		
			MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)	MAX. RESULT (Raw/Treated)	AVG. RESULT (Raw/Treated)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	
<b>TRICHALOMETHANES AND HALOACETIC ACIDS</b>															
CHLOROACETIC ACID	---	< 2.0 ug/l	OUT OF SERVICE		NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
BROMOACETIC ACID	---	< 1.0 ug/l		NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED
DICHLOROACETIC ACID	---	< 1.0 ug/l		NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED
TRICHLOROACETIC ACID	---	< 1.0 ug/l		NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED
DIBROMOACETIC ACID	---	< 2.0 ug/l		NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED
TOTAL HALOACETIC ACID	60 ug/l	< 2.0 ug/l		NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED
CHLOROFORM	50 ug/l	< 0.5 ug/l			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
BROMODICHLOROMETHANE	50 ug/l	< 0.5 ug/l			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
DIBROMOCHLOROMETHANE	50 ug/l	< 0.5 ug/l			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
BROMOFORM	50 ug/l	< 0.5 ug/l			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TOTAL TRIHALOMETHANES	80 ug/l	< 1.0 ug/l			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
<b>RADIONUCLIDES</b>															
GROSS ALPHA	15 pCi/L	< 3 pCi/L			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
GROSS BETA	50 pCi/L	< 3 pCi/L			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
RADIUM 226 & 228	5 pCi/L	< 3 pCi/L			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
TOTAL URANIUM	30 ug/l	< 3.0 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	

CONT. - CONTAMINANT

ND - NOT DETECTED

NA - NOT ANALYZED

pCi/L - pico Curies per liter

WELL NO. 4 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

LOCUST VALLEY WATER DISTRICT  
2022 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 4 N-00118 <sup>(1)</sup>		WELL NO. 5 N-00119 <sup>(1)</sup>		WELL NO. 6 N-01651 <sup>(1)</sup>		WELL NO. 7 N-05152 <sup>(1)</sup>		WELL NO. 8 N-07665 <sup>(1)</sup>		WELL NO. 9 N-014223 <sup>(1)</sup>		
			MAX. RESULT	AVG. RESULT	MAX. RESULT (raw/treated)	AVG. RESULT (raw/treated)	MAX. RESULT (raw/treated)	AVG. RESULT (raw/treated)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	
<b>UCMR3</b>															
<b>VOLATILES</b>															
1,1-DICHLOROETHANE	5.0 ug/l	0.03 ug/l	OUT OF SERVICE		ND	ND	0.59 <sup>(5)</sup> /0.75 <sup>(11)</sup>	0.12/0.36	ND	ND	ND	ND	ND	ND	
1,2,3-TRICHLOROPROPANE	5.0 ug/l	0.03 ug/l			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,3-BUTADIENE	50 ug/l	0.1 ug/l			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
BROMOCHLOROMETHANE	50 ug/l	0.06 ug/l			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
BROMOMETHANE	5.0 ug/l	0.2 ug/l			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CHLORODIFLUOROMETHANE	5.0 ug/l	0.08 ug/l			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CHLOROMETHANE	5.0 ug/l	0.2 ug/l			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
<b>PERFLUORO-CHEMICALS</b>															
PERFLUOROBUTANESULFONIC ACID	50,000 ng/l	1.8 - 2.1 ng/l			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
PERFLUOROHEPTANESULFONIC ACID	50,000 ng/l	1.8 - 2.1 ng/l			2.1 <sup>(4)</sup> /ND	0.5/ND	ND	ND	ND	ND	ND	ND	ND	ND	
PERFLUOROHXANESULFONIC ACID	50,000 ng/l	1.8 - 2.1 ng/l			3.1 <sup>(4)</sup> /ND	2.1/ND	ND	ND	ND	ND	ND	ND	ND	ND	
PERFLUORONONANESULFONIC ACID	50,000 ng/l	1.8 - 2.1 ng/l			26.9 <sup>(4)</sup> /ND	19.4/ND	ND	ND	ND	ND	ND	ND	ND	ND	
PERFLUOROOCETANESULFONIC ACID	10 ng/l	1.8 - 2.1 ng/l			4.0 <sup>(4)</sup> /ND	1.0/ND	ND	ND	ND	ND	2.0 <sup>(4)</sup>	1.0	ND	ND	
PERFLUOROOCETANOIC ACID	10 ng/l	1.8 - 2.1 ng/l			2.6 <sup>(4)</sup> /ND	1.6/ND	ND	ND	ND	ND	4.3 <sup>(4)</sup>	4.0	1.9 <sup>(4)</sup>	0.5	
PERFLUORODECANOIC ACID					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
PERFLUORODODECANOIC ACID					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
PERFLUOROHXANANOIC ACID					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
PERFLUOROUNDECANOIC ACID					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
PERFLUOROBUTANOIC ACID					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
PERLUORO(2-ETHOXYETHANE)SULFONIC ACID					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
PERFLUORO-1-HEPTANSULFONIC ACID					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
PERFLUORO-4-METHOXYBUTANOIC ACID					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
PERFLUORO-3-METHOXYPROPANOIC ACID					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
PERFLUOROPENTANOIC ACID					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
PERFLUOROPENTANESULFONIC ACID					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
NETFOSSA					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
NMeFOSSA					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
11Cl-PF64dS					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
4:2FTS					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
6:2FTS					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
8:2FTS					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
9CL-PF3ONS					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
ADONA					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
HFPO-DA					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
NFDHA					NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
<b>METALS</b>															
CHROMIUM	100 ug/l	0.2 ug/l			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
COBALT	No MCL	1.0 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
MOLYBDENUM	No MCL	1.0 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
STRONTIUM	No MCL	0.3 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
VANADIUM	No MCL	0.2 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
HEXAVELENT CHROMIUM CHLORATE	No MCL	0.03 ug/l			1.2 <sup>(1)</sup>	1.2	1.4 <sup>(1)</sup>	1.4	1.8 <sup>(1)</sup>	1.8	1.4 <sup>(1)</sup>	1.4	0.52 <sup>(1)</sup>	0.52	
	No MCL	20 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
<b>HORMONES</b>															
17-ALPHA-ETHYNYLESTRADIOL	50 ug/l	0.0004 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
17-BETA-ESTRADIOL	50 ug/l	0.0009 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
4-ANDROSTENE-3,17-DIONE	50 ug/l	0.0003 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
EQUILIN	50 ug/l	0.004 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
ESTRIOL	50 ug/l	0.0008 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
ESTRONE	50 ug/l	0.002 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
TESTOSTERONE	50 ug/l	0.0001 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	

CONT. - CONTAMINANT  
ND - NOT DETECTED  
Pg/L - PICOGRAMS PER LITER

WELL NO. 4 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

LOCUST VALLEY WATER DISTRICT  
2022 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 4 N-00118 <sup>(1)</sup>		WELL NO. 5 N-00119 <sup>(1)</sup>		WELL NO. 6 N-01651 <sup>(1)</sup>		WELL NO. 7 N-05152 <sup>(1)</sup>		WELL NO. 8 N-07665 <sup>(1)</sup>		WELL NO. 9 N-014223 <sup>(1)</sup>	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b>UCMR4</b>			OUT OF SERVICE		NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
GERMANIUM		0.3 ug/l			ND	ND	ND	ND	ND	ND	ND	ND	ND	
MANGANESE		0.04 mg/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
ALPHA-HEXACHLOROCYCLOHEXANE		0.01 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
CHLORPYRIFOS		0.03 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
DIMETHIPIN		0.2 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
ETHOPROP		0.03 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
OXYFLUORFEN		0.05 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
PROFENOFOS		0.3 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
TEBUCONAZOLE		0.2 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
TOTAL PERMETHRIN (cis- & trans-)		0.04 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
TRIBUFOS		0.07 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
BUTYLATED HYDROXYANISOLE		0.03 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
o-TOLUIDINE		0.007 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
QUINOLINE		0.02 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
1-BUTANOL		2.0 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
2-METHOXYETHANOL		0.4 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
2-PROPEN-1-OL		0.5 ug/l			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
HAA5 (5 regulated Haloacetic Acids)		None			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
HAA6Br (6 brominated Haloacetic Acids)		None			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	
HAA9 (9 Haloacetic Acids)		None			NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	NOT TESTED	

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 4 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

LOCUST VALLEY WATER DISTRICT  
2022 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 4 N-00118 <sup>(3)</sup>		WELL NO. 5 N-00119 <sup>(16)</sup>		WELL NO. 6 N-01651 <sup>(16)</sup>		WELL NO. 7 N-05152 <sup>(4)</sup>		WELL NO. 8 N-07665 <sup>(4)</sup>		WELL NO. 9 N-014223 <sup>(4)</sup>	
			MAX. RESULT	AVG. RESULT	MAX. RESULT (raw/treated)	AVG. RESULT (raw/treated)	MAX. RESULT (raw/treated)	AVG. RESULT (raw/treated)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b>VOLATILE ORGANICS</b>														
DICHLORODIFLUOROMETHANE	5.0 ug/l	0.5 ug/l	<b>OUT OF SERVICE</b>		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CHLOROMETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
VINYL CHLORIDE	2.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
BROMOMETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CHLOROETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TRICHLOROFLUOROMETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1-DICHLOROETHENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
METHYLENE CHLORIDE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TRANS-1,2-DICHLOROETHENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1-DICHLOROETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	0.59/0.75	0.1/0.3	ND	ND	ND	ND	ND
<i>cis</i> -1,2 DICHLOROETHENE	5.0 ug/l	0.5 ug/l		ND	ND	3.1/ND	1.5/ND	1.1/1.1	0.7/0.6	ND	ND	ND	ND	ND
2,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
BROMOCHLOROMETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,1-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CARBON TETRACHLORIDE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-DICHLOROETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TRICHLOROETHENE	5.0 ug/l	0.5 ug/l		ND	ND	1.0/ND	0.5/ND	0.75/ND	0.6/ND	ND	ND	ND	ND	ND
1,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
DIBROMOMETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TRANS-1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
<i>cis</i> -1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
1,1,2-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
TETRACHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	3.9/ND	2.2/ND	2.4/ND	1.8/ND	ND	ND	ND	ND	ND	

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 4 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR



LOCUST VALLEY WATER DISTRICT  
2022 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 4 N-00118 <sup>(3)</sup>		WELL NO. 5 N-00119 <sup>(16)</sup>		WELL NO. 6 N-01651 <sup>(16)</sup>		WELL NO. 7 N-05152 <sup>(4)</sup>		WELL NO. 8 N-07665 <sup>(4)</sup>		WELL NO. 9 N-014223 <sup>(4)</sup>		
			MAX. RESULT	AVG. RESULT	MAX. RESULT (raw/treated)	AVG. RESULT (raw/treated)	MAX. RESULT (raw/treated)	AVG. RESULT (raw/treated)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	
<b>VOLATILE ORGANICS (CONT'D.)</b>															
1,3-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	<b>OUT OF SERVICE</b>		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
CHLOROBENZENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,1,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
BROMOBENZENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,2,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2,3-TRICHLOROPROPANE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
2-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
4-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,3-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,4-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2,4-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
HEXACHLOROBUTADIENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2,3-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
BENZENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TOLUENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
ETHYLBENZENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
M,P-XYLENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
O-XYLENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
STYRENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
ISOPROPYLBENZENE (CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
N-PROPYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
1,3,5-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 4 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

LOCUST VALLEY WATER DISTRICT  
2022 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 4 N-00118 <sup>(3)</sup>		WELL NO. 5 N-00119 <sup>(16)</sup>		WELL NO. 6 N-01651 <sup>(16)</sup>		WELL NO. 7 N-05152 <sup>(4)</sup>		WELL NO. 8 N-07665 <sup>(4)</sup>		WELL NO. 9 N-014223 <sup>(4)</sup>	
			MAX. RESULT	AVG. RESULT	MAX. RESULT (raw/treated)	AVG. RESULT (raw/treated)	MAX. RESULT (raw/treated)	AVG. RESULT (raw/treated)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<b>VOLATILE ORGANICS (CONT'D.)</b>														
TERT-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	<b>OUT OF SERVICE</b>		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2,4-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
SEC-BUTYLBENZENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
4-ISOPROPYLTOLUENE (P-CUMENE)	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
N-BUTYLBENZENE	5.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
METHYL TERT.BUTYL ETHER (MTBE)	10.0 ug/l	0.5 ug/l		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 4 - OUT OF SERVICE

( ) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR